TOWN OF SOUTHBURY
OFFICE OF THE FIRE MARSHAL

PERIORDIC TESTING OF EMERGENCY LIGHT EQUIPMENT
CT LIFE SAFETY CODE.

Section 14.13.2.2.1 (1), (2) & (4) "A functional test shall be conducted on every required battery-powered emergency lighting system at 30 clay intervals for a minimum of 30 seconds. An annual test shall be conducted for a 1-1/2 hour duration. Equipment shall be fully operational for the duration of the test. Written records of visual inspections and tests shall be kept by the owner for inspection by the authority having jurisdiction."

LIGHT #													
Location Description													
		Date	By	Date	By	Date	By	Date	By	Date	By	Date	By
MONTHLY 30 SECOND TEST	JAN.												
	FEB.												
	MAR.												
	APRIL												
	MAY												
	JUNE												
	JULY												
	AUG												
	SEPT												
	OCT												
	NOV.												
	DEC.												
ANNUAL 90 MIN TEST													