

PEDESTRIAN SAFETY IMPROVEMENTS
STATE PROJECT #0130-0194
ADDENDUM 1

1. There is a bid item 0406003A Permanent Paving in the above referenced project specifications. Will temporary asphalt be necessary, or can we install the permanent paving immediately after the adjacent sidewalk and conduit trench is installed? If temporary asphalt will be required, there is no pay item for it.
 - A. Item #406003A is for Pavement Repair. Temporary pavement is not required.